

NTPC LTD

CC-OS

EOC NOIDA

Sub: Qualifying Requirement for Vendor Enlistment for supply of “Fire Fighting Hoses”

| | | | |
|----|---|---|----------------------------|
| A) | MEG DETAILS | | |
| | 1.0 | MEG NO. | 16MEC-11 |
| | 2.0 | MEG DESCRIPTION | Fire Fighting Hoses |
| | 3.0 | RESPONSIBILITY CENTRE | ER-II |
| B) | Technical Criteria of QR: 1. The applicant should be a manufacturer of Fire Fighting Hose 2. The applicant should have valid BIS License for IS 636 3. The applicant should have supplied Fire Fighting Hoses as per IS:636 | | |
| C) | Other Documents to be submitted: In addition to the documents required in support of meeting technical requirements as stated above, following documents are required to be submitted by the Applicants applying for enlistment:- 1. Three POs of the highest executed values of similar work during previous five years from the date of application. Copy of Invoice / Completion certificate from the concerned buyer/s in support of successful execution of supply against the POs to be submitted. 2. Audited balance sheet including Profit & Loss statement for the previous three completed financial years reckoned from the date of application. In case the audited documents are not ready / available, then certified copy by a registered practicing Chartered accountant may be submitted. 3. Latest annual report OR NSIC / SSI / MSME registration certificate / BIS license / ISO certificate / Certificate of registration from the concerned excise department / any other statutory document as a proof of being manufacturer of the required material. 4. Any other documents in addition to the above which the applicant wants to submit. | | |
| D) | NOTE-1 | Similar works means: Supply of Fire Fighting Hoses as per IS:636 in last 5 years | |
| | NOTE-2 | The executed value means Basic value of quantity of similar works executed/supplied against the reference PO(also applicable to partly executed POs as on date of application).Where PO value is composite(i.e. including Taxes etc.),the applicant to give item-wise break-up of Composite PO value mentioning Basic Value, Taxes etc. | |

NTPC LTD

CC-OS

EOC NOIDA

Sub: Technical Specifications for Vendor Enlistment for supply of “Fire Fighting Hoses”

| | | | |
|----|--|-----------------------|----------------------------|
| A) | MEG DETAILS | | |
| | 1.0 | MEG NO. | 16MEC-11 |
| | 2.0 | MEG DESCRIPTION | Fire Fighting Hoses |
| | 3.0 | RESPONSIBILITY CENTRE | ER-II |
| B) | Technical Specifications: <ol style="list-style-type: none">1. Hoses should be BIS marked2. Hose to be of Type – A* or Type –B* (as mentioned in Cl- 3.1.1 or 3.1.2 in IS: 636) as mentioned in the requirement.3. End connections* shall be Gunmetal/ Aluminum/ SS as mentioned in the requirement.4. Length* of the hoses shall be as per requirement <i>NB:</i> <i>In the PR, indenter to put Selection / Value to be put in * marked criteria</i> | | |