



Bid Number/बोली क्रमांक (बिड संख्या):
GEM/2023/B/4340055
Dated/दिनांक : 18-01-2024

Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण	
Bid End Date/Time/बिड बंद होने की तारीख/समय	07-02-2024 15:00:00
Bid Opening Date/Time/बिड खुलने की तारीख/समय	07-02-2024 15:30:00
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	120 (Days)
Ministry/State Name/मंत्रालय/राज्य का नाम	Ministry Of Power
Department Name/विभाग का नाम	Na
Organisation Name/संगठन का नाम	Ntpc Limited
Office Name/कार्यालय का नाम	Ssc Coal Mining Ntpc
Total Quantity/कुल मात्रा	3
Item Category/मद केटेगरी	High Mast Lighting Tower for large area with LED Flood Lighting System (Q3)
MSE Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से एमएसई छूट	No
Startup Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से स्टार्टअप छूट	No
Document required from seller/विक्रेता से मांगे गए दस्तावेज़	Certificate (Requested in ATC),Additional Doc 1 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया	No
Type of Bid/बिड का प्रकार	Two Packet Bid
Primary product category	High Mast Lighting Tower for large area with LED Flood Lighting System
Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय	2 Days
Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Evaluation Method/मूल्यांकन पद्धति	Total value wise evaluation

EMD Detail/ईएमडी विवरण

Required/आवश्यकता	No
-------------------	----

ePBG Detail/ईपीबीजी विवरण

Required/आवश्यकता	No
-------------------	----

Splitting/विभाजन

Bid splitting not applied/बोली विभाजन लागू नहीं किया गया.

Reserved for Make In India products

Reserved for Make In India products	Yes
-------------------------------------	-----

MSE Purchase Preference/एमएसई खरीद वरीयता

MSE Purchase Preference/एमएसई खरीद वरीयता	Yes
---	-----

1. Bid reserved for Make In India products: : Procurement under this bid is reserved for purchase from Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. However, eligible micro and small enterprises will be allowed to participate. The minimum local content to qualify as a class 1 local supplier is denoted in the bid document. All bidders must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which the bid is liable to be rejected. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020 . In case Buyer has selected Purchase preference to Micro and Small Enterprises clause in the bid, the same will get precedence over this clause.

2. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% (Selected by Buyer)of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for 100%(selected by Buyer) percentage of total QUANTITY.The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

3. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

High Mast Lighting Tower For Large Area With LED Flood Lighting System (1 pieces)
(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)

Technical Specifications/तकनीकी विशिष्टियाँ

* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	Height of High Mast Tower (in Meters)	16
	Installation and commissioning (Installation and commissioning work at multiple locations shall follow as per the guidelines of State/Central Govt rules and regulations as applicable)	Yes. Including civil work for mining sites (for mining sites all Electricals, winch mechanism, lamps control-gears, breakers, cables etc shall be suitable for 230 V (L-L), 50 Hz supply and with RCCB/ELCB based protection provided with suitable range to comply relevant CEA regulation 42
	Onsite warranty (in Years)	2
High mast System	No of sections	2
	Effective length of each section (in m)	10
	Material construction: The mast shall be manufactured using special steel plates, conforming to	355 grade as per BSEN10 025
	Bottom diameter (in mm) - Minimum	540
	Plate thickness for Middle (in mm) - Minimum	4
	Plate thickness for Bottom (in mm) - Minimum	5
	No of longitudinal welds / section (in Nos)	1
	Diameter of base plate (in mm) - Minimum	740
	Thickness of base plate (in mm) - Minimum	25
Wind Load	Maximum Wind load	50 m/sec
Door Opening	Size of opening and closing door at base compartment of high mast (in mm) - Minimum	1200 x 250

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Junction Box	Ingress protection for Junction Box i.e. IP Class (as per IS/IEC:60529:2001 latest) Test Report from Central Government lab/NABL/ILAC accredited lab and report shall furnish to buyer on demand	IP 65
	No of core	3
	Cable category	FR
	Size of cable (in Sq mm)	2.5
	Conductor material shall be	Copper
Winch	The winch shall have provision for manual operation in case of failure of the motor	Yes
Stainless Steel Wire Rope	The breaking load of each rope shall be at full load as per the relevant standard	>/=2250Kg
Electrical System, Cable and Cable Connections	No. of cores	3
	Cable shall be	Armoured
	Conductor material shall be	Copper
	Cable Category	1
	Incoming power cable from feeder panel to base compartment of mast and cable shall conforming to	IS:7098 (Part 1):1988 latest
Feeder pillar Panel	Feeder pillar panel for each mast	Yes
	Feeder panel shall be suitable for	230 V (L-L), 3 phase, AC 50 Hz (for Mining area)for Mining sites all electricals, winch mechanism, lamps control-gears, breakers, cables etc shall be suitable for 230V(L-L), 50 Hz supply
	The control panels shall be	Stand mounted
	Ingress protection for feeder pillar panel i.e IP Class (as per IS/IEC:60529:2001 latest).Test Report shall furnish from Central Government lab/NABL/ILAC accredited lab to buyer on demand	IP 55
	It shall be fabricated out of	14 SWG CRCA sheet steel
	Thickness of sheet (in mm)	2

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	The panels shall be given pre-treatment and powder coated and color shall be	Grey
	The stand shall be painted in	Black color
	Cable entry shall be at the	Bottom
	The panels shall have	knock outs of the required cable
	Laminated circuit diagram shall be pasted	inside of the door
	Feeder pillar shall have pad locking arrangement	Yes
	Earth terminal	12 mm dia. Bolts
	Panel shall have a sloping cover to avoid accumulation of dust	Yes
	Panel shall be provided with incoming & outgoing MCCB / MCB of appropriate rating and in desired quantity depending on total no of circuits in use	yes
	Timer for automatic ON & OFF of lights with pilot lamps shall be provided	Yes
	Bus bars material	Yes. Copper
	No of Cores	3
	Size of cable (in Sq.mm)	2.5
	Cable Shall be	Armoured
	The conductor material shall be	Copper
	cable category	1
LED FLOOD LIGHT LUMINAIRE	No. of Luminaires for each high mast lighting tower (in Nos)	12
	LED Rating/System Wattage/Rated Power for each luminaire	350W
	Luminaire System Efficacy (Lumen/watt)	>/= 100 Lm/Watt
	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest	IP65
	Mounting brackets (included)	Adjustable

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Input operating Voltage range and frequency	90 to 300 Volts AC at 50Hz+/-2Hz
	Rated voltage	230 V AC 50 Hz
	Colour temperature	6000K (+/- 500K)
	Optic lense material (UV stabilised) (Write NA for without optic lense supply)	Poly carbonate lense
	Operating temperature range	-20 deg C to +50 deg C
	The luminaire shall be protected against surges and transients(Internal)	>/=5KV
	Number of electronic control gear per luminaire (power supplies)	4 Nos.
	Length of ISI marked three core wire (shall be provided along with supply of material)	50 cm

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	S Gopi	496111,Talaipalli Coal Mining Projects, Lailunga Road, Gharghoda, Raigarh Chhattisgarh	1	90

High Mast Lighting Tower For Large Area With LED Flood Lighting System (2 pieces)
(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)

Technical Specifications/तकनीकी विशिष्टियाँ

[* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	Height of High Mast Tower (in Meters)	20
	Installation and commissioning (Installation and commissioning work at multiple locations shall follow as per the guidelines of State/Central Govt rules and regulations as applicable)	Yes. Including civil work for mining sites (for mining sites all Electricals, winch mechanism, lamps control-gears, breakers, cables etc shall be suitable for 230 V (L-L), 50 Hz supply and with RCCB/ELCB based protection provided with suitable range to comply relevant CEA regulation 42
	Onsite warranty (in Years)	2
High mast System	No of sections	2
	Effective length of each section (in m)	10
	Material construction: The mast shall be manufactured using special steel plates, conforming to	355 grade as per BSEN10 025
	Bottom diameter (in mm) - Minimum	540
	Plate thickness for Middle (in mm) - Minimum	4
	Plate thickness for Bottom (in mm) - Minimum	5
	No of longitudinal welds / section (in Nos)	2
	Diameter of base plate (in mm) - Minimum	740
	Thickness of base plate (in mm) - Minimum	25
Wind Load	Maximum Wind load	50 m/sec
Door Opening	Size of opening and closing door at base compartment of high mast (in mm) - Minimum	1200 x 250
Junction Box	Ingress protection for Junction Box i.e. IP Class (as per IS/IEC:60529:2001 latest) Test Report from Central Government lab/NABL/ILAC accredited lab and report shall furnish to buyer on demand	IP 65
	No of core	3
	Cable category	FR
	Size of cable (in Sq mm)	2.5

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Conductor material shall be	Copper
Winch	The winch shall have provision for manual operation in case of failure of the motor	Yes
Stainless Steel Wire Rope	The breaking load of each rope shall be at full load as per the relevant standard	>/=2400 Kg
Electrical System, Cable and Cable Connections	No. of cores	4
	Cable shall be	Armoured
	Conductor material shall be	Aluminium
	Cable Category	C1
	Incoming power cable from feeder panel to base compartment of mast and cable shall conforming to	IS:7098 (Part 1):1988 latest
Feeder pillar Panel	Feeder pillar panel for each mast	Yes
	Feeder panel shall be suitable for	415 V, 3 phase, 4 wire, 50 Hz, AC
	The control panels shall be	Stand mounted
	Ingress protection for feeder pillar panel i.e IP Class (as per IS/IEC:60529:2001 latest). Test Report shall furnish from Central Government lab/NABL/ILAC accredited lab to buyer on demand	IP 65
	It shall be fabricated out of	14 SWG CRCA sheet steel
	Thickness of sheet (in mm)	2
	The panels shall be given pre-treatment and powder coated and color shall be	Grey
	The stand shall be painted in	Black color
	Cable entry shall be at the	Bottom
	The panels shall have	knock outs of the required cable
	Laminated circuit diagram shall be pasted	inside of the door
	Feeder pillar shall have pad locking arrangement	Yes
Earth terminal	12 mm dia. Bolts	

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Panel shall have a sloping cover to avoid accumulation of dust	Yes
	Panel shall be provided with incoming & outgoing MCCB / MCB of appropriate rating and in desired quantity depending on total no of circuits in use	yes
	Timer for automatic ON & OFF of lights with pilot lamps shall be provided	Yes
	Bus bars material	Yes. Copper
	No of Cores	1
	Size of cable (in Sq.mm)	2.5
	Cable Shall be	Unarmoured
	The conductor material shall be	Copper
	cable category	1
LED FLOOD LIGHT LUMINAIRE	No. of Luminaires for each high mast lighting tower (in Nos)	12
	LED Rating/System Wattage/Rated Power for each luminaire	350W
	Luminaire System Efficacy (Lumen/watt)	>/= 100 Lm/Watt
	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest	IP65
	Mounting brackets (included)	Adjustable
	Input operating Voltage range and frequency	90 to 300 Volts AC at 50Hz+/-2Hz
	Rated voltage	230 V AC 50 Hz
	Colour temperature	6000K (+/- 500K)
	Optic lense material (UV stabilised) (Write NA for without optic lense supply)	Poly carbonate lense
	Operating temperature range	-10 deg C to +55 deg C
The luminaire shall be protected against surges and transients(Internal)	>/=4KV	

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Number of electronic control gear per luminaire (power supplies)	4 Nos.
	Length of ISI marked three core wire (shall be provided along with supply of material)	50 cm

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	S Gopi	496111,Talaipalli Coal Mining Projects, Lailunga Road, Gharghoda, Raigarh Chhattisgarh	2	90

Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें

1. Scope of Supply

Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods

2. Generic

Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

3. Generic

Bidder shall submit the following documents along with their bid for Vendor Code Creation:

- Copy of PAN Card.
- Copy of GSTIN.
- Copy of Cancelled Cheque.
- Copy of EFT Mandate duly certified by Bank.

4. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

Disclaimer/अस्वीकरण

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. Any clause(s) incorporated by the Buyer regarding following shall be treated as null and void and would not be considered as part of bid:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process.
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।

---Thank You/धन्यवाद---