

BRIEF SCOPE AND TECHNICAL SPECIFICATIONS FOR “Supply and Installation of 6.6 kV Vacuum Circuit Breakers at NTPC Kawas”

The scope of the specification covers design, manufacture, testing, supply, retrofitting at site in place of existing 6.6 kV, 630 A breakers of GEC-ALSTHOM with complete Vacuum Circuit breaker (VCB) truck and testing and commissioning inclusive of necessary tools and tackles and supply of mandatory spares as per the list in the Bill of Quantity (BOQ). Detailed specifications of the items are specified in the bidding documents.