

Salient Technical Feature

“Salient Technical Features of the equipment are mentioned below. These Salient Technical Features are mentioned only to facilitate the prospective bidders to prima-facie understand the requirements under the tender and shall not in any way limit or alter the scope of work and technical features/specification of equipment/ systems/ services covered in the Bidding Documents. Detailed provisions in regard of scope of work and technical features/specification of equipment contained in the Bidding Document shall be final and binding.”

Name of the Project	SCADA & WMS Package for Solapur Solar PV Plant Maharashtra
Supply Quantity	As per Technical Specification

- Supply of redundant RTU/DDC/PLC Based SCADA with Software, 1 OWS cum EWS, 1 OWS with RTU/ Remote I/O at Inverter Location and Ring network with all accessories, Panel, LIU, Power supplies complete in all respect.
- Weather Monitoring System consisting pyranometer, thermometer and datalogger as per the specification.
- Supply and installation of Power Plant controller as per the specification.
- Supply & installation of Microprocessor based Fire Alarm Panel with multisensor smoke detector in the rooms buildings defined in the specification.