

Salient Technical Features

“Salient Technical Features of the equipment are mentioned below. These Salient Technical Features are mentioned only to facilitate the prospective bidders to prima-facie understand the requirements under the tender and shall not in any way limit or alter the scope of work and technical features/specification of equipment/ systems/ services covered in the Bidding Documents. Detailed provisions in regard of scope of work and technical features/specification of equipment contained in the Bidding Document shall be final and binding.”

Name of the Project	HT POWER CABLE SUPPLY PACKAGE OF 1255 MW BLOCK OF KHAVDA RE PARK
Supply Quantity	835 kms (breakup as furnished below)

- Supply 15 kms of 19/33 kV, 1C×185 sq.mm, FRLS cable (90% Armour Coverage), as per IS:7098-2.
- Supply of 820kms of 19/33 kV 1C×300 sq.mm FRLS cable (90% Armour Coverage), as per IS:7098-2.